

# Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2024/ 3921

Dated:- 16-12-2024

## WATER TEST REPORT

ADDRESS:- ST. THOMAS SCHOOL, GYAN KHAND II, INDIRAPURAM, GHAZIABAD.

PREVIOUS SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
N/A	N/A	N/A	N/A	N/A

No of sample collected : 01

SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
13-12-2024	RO WATER	DRINKING	3809	Satisfactory

### Test Result

H<sub>2</sub>S Water test kit : Negative (-Ve) after 24-48 hrs incubation

### Comments:-


H<sub>2</sub>S water test kit report - ve reflects that water is free from Coliforms Organism.

### Recommendation:

Given water safe for drinking purpose.

- This Satisfactory report/result is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.
- Validity upto 03 months.

Lab Technician  
IDSP Lab  
Ghaziabad

  
(Dr R.K Gupta)  
District Public Health Expert  
Ghaziabad  
District Public Health Expert  
District Ghaziabad